



City of Glendale, AZ

Technical Guideline

Building Inspection Department

Technical Guideline

Interpretation

Modification

Issue Date: August 10, 2016
Code/Section:
Approved: Stephen Dudley—Building Official
Developed by: Mechanical/Plumbing Staff
References:

Issue: Fuel Gas Piping to Generators

Guideline:

For Fuel Gas (Natural Gas or LPG) Generator Installations:

Whenever a generator is installed (whether it is required by code or by design) there shall be a separate fuel gas pipe installed exclusively for the purpose of operating the generator.

This pipe shall have a listed and approved valve located on the discharge side of the gas meter (or the discharge side of the LPG storage tank) at the gas meter or storage tank location and shall be “LOCKED OPEN” and shall be permanently identified as “GENERATOR NATURAL GAS (or LPG) SUPPLY”.

There shall also be a listed and approved valve located on the discharge side of the gas meter or LPG storage tank at the gas meter or LPG storage tank location that is permanently identified as “BUILDING NATURAL GAS (or LPG) SUPPLY”.