



City of Glendale, AZ

Technical Guideline

Building Inspection Department

Technical Guideline

Interpretation

Modification

Issue Date: February 21, 2017
Code/Section: 2012 International Plumbing Code Section 1106.5
Approved: Stephen Dudley—Building Official
Developed by: Mechanical/Plumbing staff
References: 2012 Uniform Plumbing Code, City of Phoenix amendments

Issue: Sizing method for scuppers and overflow scuppers

Guideline:

When scuppers are used for primary and/or secondary roof drainage, the openings shall not be less than 4" in height and have an opening width equal to the circumference of the roof drain required for the area served.